

## MATHEWS PARK PAVILIONS Q&A

AUGUST 16, 2021

- Is the City open to extending the deadline for completion considering fabrication for a product of this size can take 15+ weeks?

Offeror will provide an anticipated number of days for project completion.

- For the pavilion being installed into an existing slab, would the City be open to installing the pad into new footers just outside the width of the slab? The footers could be installed flush with the existing slab. My fear is that cutting into the concrete so close to the edge will cause it to crack.

You should not be cutting into the existing slab. The posts are to be mounted on top of the existing slab with steel plates and wedge anchors.

- In composing the bid package for later this month, I came across a portion of the Addenda #1 that I was unclear on. In compiling our references, are we to write the letters for the (3) subcontractors or are we to collect the reference letters from them?

The reference letters are for the General Contractor who will be submitting the bid.

- Will this be permitted through Monroe or Walton County?

No permits will be required for this project.