



Utility Committee Meeting

AGENDA

October 6, 2015

I. CALL TO ORDER

II. MATTERS BEFORE COMMITTEE

1. [Approval - Repair of Aerial Sewer Main](#)
2. [Approval - Purchase of Variable Frequency Drives for High Service Pumps](#)
3. [Discussion - Clubhouse Utilities](#)

III. ADJOURN



Utility Committee Meeting

AGENDA

October 6, 2015

Item:

Approval - Repair of Aerial Sewer Main

Department:

Additional Information:

Financial Impact:

Budgeted Item:

Recommendation / Request:

Viewing Attachments Requires Adobe Acrobat. [Click here](#) to download.

Attachments / click to download

 [Aerial Repair Info](#)

Repair of aerial sewer main along Hwy 83

Rutledge Crane Service Inc.	\$	27,750.00
E.R. Snell	\$	45,800.00

From: Bryan Pittman [<mailto:bpittman65@gmail.com>]
Sent: Friday, August 28, 2015 8:29 AM
To: Rodney Middlebrooks
Subject: Fwd: Sewer Pipe Proposal

Sent from my iPhone

Begin forwarded message:

From: <tony@rutledgecraneservice.com>
Date: August 27, 2015 at 4:29:45 PM EDT
To: <bpittman65@gmail.com>
Subject: Sewer Pipe Proposal

PROPOSAL



Rutledge Crane Service Inc.
535 Harvey Lokey Rd.
Bethlehem GA 30620
Office: 770-867-1986
Cell: 678-227-3643

Customer Name:

Address:

City: State: Zip:

Phone#: Fax #:

Job Name: Location:

Contact Name:

Brian Pittman

Email address:

bpittman65@gmail.com

Description of Work:

Scope of work for the project is to install steel pilings on each side of the sewer line.
Sewer line will be raised back to grade and attached to steel structure.
City of Monroe is responsible for getting approval and all necessary safety precautions,
communications and paperwork with Georgia Power in order to be in compliance
with working next to their power lines. City of Monroe is responsible for having the
area cleared and prepared for the project work. Rutledge Crane Service will not be
responsible for cracked or damage pipe. Proposal includes labor, equipment and materials
for the project. Materials will include 12" H Pile that will be welded in place to support
the pipe. Equipment used will be bridge crane, pile driving rig, track hoe and bobcat.

TOTAL AMOUNT DUE:

\$27,750.00

Customer's Signature

Date:

8/27/2015

**CASH OR CHECK DUE UPON COMPLETION UNLESS PRIOR ARRANGEMENTS
HAVE BEEN MADE**

*** This is an approximation of the total dollar amount. Without knowing the number of hours, we will be on the job site, we won't know the total dollar amount until we have completed the job.***

Rodney Middlebrooks

From: Bryan Pittman [bpittman65@gmail.com]
Sent: Thursday, September 10, 2015 1:26 PM
To: Rodney Middlebrooks
Subject: Re: Quote

Sent from my iPhone

On Sep 10, 2015, at 11:51 AM, Bryan Pittman <bpittman65@gmail.com> wrote:

Sent from my iPhone

Begin forwarded message:

From: Randy Griffin <rgriffin@ersnell.com>
Date: September 10, 2015 at 11:11:08 AM EDT
To: Tom Clower <tclower@ersnell.com>, "bpittman65@gmail.com" <bpittman65@gmail.com>
Subject: Quote

Mr. Pittman,

Your price quotation for the work that you and Mr. Tom Clower met and discussed is \$45,800.00

Our price includes all labor, materials, and equipment necessary.

It is not in our scope of work to handle clearing, access to the site, or providing a safe work zone in reference
If our price is low and you need an official quote, please contact Tom Clower. Thank you.

Randy Griffin, P.E.
Vice President
E.R. Snell Contractor, Inc.
Office (770) 985-0600
Cell (770) 827-9949



Utility Committee Meeting

AGENDA

October 6, 2015

Item:

Approval - Purchase of Variable Frequency Drives for High Service Pumps

Department:

Additional Information:

Financial Impact:

Budgeted Item:

Recommendation / Request:

Viewing Attachments Requires Adobe Acrobat. [Click here](#) to download.

Attachments / click to download

 [Pump Info](#)

Purchase VFD's for High Service pumps @ Water Treatment Plant

Tekwell	\$	20,322.44
PMC	\$	20,062.72
DriveTech	\$	32,540.00
Pumping Systems	\$	38,016.00



9/24/15

City of Monroe Water
Doug Samples
404-392-1163
dsamples@monroega.gov

Quotation for Fuji Drives and Installation

Tekwell is proud to offer the following quotation:

- FRN250G1S-4U Fuji Mega Core Drive Qty. 1
 - 460 volt, 3 phase, 250HP, 304A, LD
 - \$7,812.69 Each (Does not include freight)
- Drive Installation- High Service Pump #1
 - Travel to and from job site- Date to be determined
 - Remove existing soft start
 - Install new drive, start up and tune with customer supplied remote operator
 - \$2,348.53
 - Installation does not include replacing any existing timers, relays, or contactors

- Total Job Cost- \$10,161.22

Please feel free to contact us with any questions. Thank you for the opportunity to provide you with this quote.

Sincerely,

Tekwell Services





240 Industrial Park Drive
 Forsyth, Georgia 31029
 Phone: 470-994-2040
 Fax: 470-994-6057

Quote

www.pmc enterprises.com

Customer Number	Quote Date	Quote Number
09947	2/25/2015	255016984

Quote To:

Monroe, City of
 P.O. Box 1249
 Monroe, GA 30655

Ship To:

City of Monroe
 215 North Broad Street
 Monroe, GA 30655

Ship Via	Terms	Quoted By	Customer RFQ	Contact
Bestway	Net 30	Walter Alexander		Doug Samples

Product ID	Qty	Description	Sales Price	Total
A510-4215-C3	2	TECO-Westinghouse A510 Heavy Duty AC Drive, 215HP CT / 250HP VT, Amps 295.0 CT/ 328.0 VT, 3 Phase, 460 Volts, Protected Chassis, Approx wt 200Lbs	9,582.86	19,165.72
JN5-NK-A07	2	A510 Frame 7 NEMA 1 Kit 75-100 230V - 125HP and above 460V	448.50	897.00

<p><i>Quote is valid for 30 days</i></p> <p>Only two drives in stock in Texas, We have them on a 48 hour hold, waiting approval</p> <p>Thank You</p>	Subtotal:	20,062.72
	Freight:	0.00
	Other:	0.00
	0.000 % Sales Tax 1:	0.00
	0.000 % Sales Tax 2:	0.00
	Total:	20,062.72

WE WILL NOT PROCEED ON REPAIRS / REPLACE UNTIL AUTHORIZATION IS RECEIVED!

Page 1 of 1

SIGNATURE: _____ DATE: _____

PO# (IF NOT ALREADY ISSUED): _____

Item # 2

DRIVETECH

P.O. BOX 605
 HULL, GA 30646
 PH. 706-543 3388
 FAX 706 543-2668

QUOTE

Date	Estimate #
3/3/2015	101117

Name / Address
CITY OF MONROE P O BOX 1249 MONROE, GA 30655

			Project
Description	Qty	Cost	Total
(1) 250 HP VARIABLE FREQUENCY DRIVE FOR HIGH SERVICE PUMP. ** DOES NOT INCLUDE FREIGHT**	1	16,270.00	16,270.00
THANK YOU FOR THE OPPORTUNITY. QUOTE IS GOOD FOR 30 DAYS.		Total	\$16,270.00

Item # 2

FW: 150302-BRMA Quotation to City of Monroe for VFD replacement

X DELETE ← REPLY ⇐ REPLY ALL → FORWARD ...

Mark as unread



Cathy Halgat

Tue 3/3/2015 3:58 PM

To: Doug Samples;

Doug,

Here is the quote from Pumping Systems for the high service pump VFDs.

Cathy

From: Berend Morrison [mailto:bmorrison@pumping-systems.com]
Sent: Monday, March 02, 2015 2:54 PM
To: Cathy Halgat
Cc: Scott Schutz
Subject: 150302-BRMA Quotation to City of Monroe for VFD replacement

Ms. Halgat,

Good afternoon. Please see the following information for the subject quotation. Please review it and let us know if you have any questions. Thanks for your time and have a great day.

Item	Qty	Tag / Equipment ID	Product ID	Description
1	2		ACS880-01-361A-5	ACS880 Drive Wall Mounted. Input Voltage 480 VAC. 361A LD, 302A HD. IP21 - UL type 1. Frame Size -R9
1.1	2		+DPMP-01	Panel cabinet door mounting kit - DPMP-01

Net Price: \$38,016.00

Regards,
 Berend Morrison
 Application Engineer/
 IT Manager

6/30/201
 Item # 2



Utility Committee Meeting

AGENDA

October 6, 2015

Item:

Discussion - Clubhouse Utilities

Department:

Additional Information:

Financial Impact:

Budgeted Item:

Recommendation / Request:

Viewing Attachments Requires Adobe Acrobat. [Click here](#) to download.

Attachments / click to download